

Article

Active, Reactive and Harmonic Control for Distributed Energy Micro-Storage Systems in Smart Communities Homes

Maria-Isabel Milanes-Montero ^{1,*}, Fermin Barrero-Gonzalez ¹, Jaime Pando-Acedo ¹,
Eva Gonzalez-Romera ¹, Enrique Romero-Cadaval ¹ and Antonio Moreno-Munoz ²

¹ Department of Electrical, Electronic and Automation Engineering, University of Extremadura, Badajoz 06006, Spain; fbarrero@unex.es (F.B.-G.); jpandoac@peandes.es (J.P.-A.); evagzlez@unex.es (E.G.-R.); eromero@unex.es (E.R.-C.)

² Department of Computer Architecture, Electronics and Electronic Technology, Universidad de Córdoba, Córdoba 14071, Spain; a.moreno@ieee.org

* Correspondence: milanes@unex.es; Tel.: +34-924-289600

Academic Editor: Rodolfo Araneo

Received: 8 February 2017; Accepted: 24 March 2017; Published: 1 April 2017

Abstract: This paper aims to provide control strategies for distributed micro-storage energy systems at the residential level to contribute to smart grid goals. A simulation model of an energy storage system (ESS) charger has been implemented to test these proposed control strategies. The smart community energy management system (SCEMS), acting as an aggregator of resources in the community according to the expected demand and production, sends to each individual home the active and reactive power set-points. Besides, in case the ESS has available capacity, once the SCEMS requirements are satisfied, it is used to absorb the harmonic current components demanded by the household circuitry. It allows a local improvement in the power quality of the demanded current, and thus contributes to the global power quality consumption of the community. Simulation results showing the operation of a local ESS at a home in a Smart Community are presented to validate the proposed control strategies.

Keywords: energy storage systems (ESSs); energy management systems; smart communities; micro-storage systems; active control; reactive control; harmonic control

1. Introduction

The idea of the so called Smart Communities [1,2] is supported by the following facts: the rising trend in electricity demand, the increase of distributed generation based on renewable resources and the great advance in energy storage systems research.

The energy demanded by a community could be provided by the generators owned by the consumers themselves. This can be done either directly (if the time period of consumption match that of the non-manageable energy production) or indirectly by means of an energy storage system. With a proper management, an important savings in the electricity bill will be achieved [3].

Owners of distributed generators, usually non-manageable (photovoltaic or wind units) located in the vicinity of consumers, could take advantage of selling their energy locally, or they can sell electrical energy to the market at time periods in which the price is higher, regardless of the generation timetable [4]. From the point of view of the grid, demand side management and smoothing of the power injected into the grid by the distributed generators, facilitate the distribution grid operation [5].

In this situation, energy storage systems (ESSs) are essential for the energy management system of the smart community [6]. Most of the attention in the technical literature has been paid to the research

on the design of large storage capacity (10–100 MWh) equipment. However, in the last years, research has been focused on the use of distributed micro-storage systems with a smaller capacity (few kWh). These micro-storage systems, shared by several homes in a community, allow consumers to keep stored a small amount of energy to take over the peaks in its demand and to smooth the variability of their own renewable energy supply. A central smart community energy management system (SCEMS) is responsible for the control of these equipment, acting as an aggregator of resources and coordinating them to assure benefits for the whole community. The SCEMS generates and sends to each local ESS the set-points for both active and reactive power for charging/discharging, according to the demand and production.

Additionally, these systems should not get worse the power quality. Indeed, most battery chargers for ESS on the market demand harmonic currents and reactive power and, as a consequence, the massive installation of battery chargers leads to a deterioration of power quality in the distribution grid [7]. This shows the need for research into new control strategies applicable to the energy storage management system (ESMS) to guarantee that these chargers operate according to the smart grid goals and policies [8].

The objective of this work is to contribute to this line of research. Thus, control strategies for the ESMS to meet the active and reactive power set-points received from the SCEMS have been proposed. These strategies will improve the performance of the ESS and the quality of the current waveform demanded by the charger. Besides, in case the ESS has got available capacity, once the SCEMS requirements are satisfied, it is used to absorb the harmonic current components demanded by the household circuitry. It allows a local improvement in the power quality of the demanded current, and so contributes to the global power quality consumption of the community. Most bidirectional chargers found in the technical literature focus on the active power flow control and few works address a reactive power flow control. However, the benefits of including a local harmonic control strategy, operating simultaneously with the active and reactive controllers, have not been further investigated. The main contributions of the paper are:

- The proposal of a strategy to control fundamental reactive power, able to operate properly under distorted grid voltage,
- The harmonic control strategy with saturated function, to assure the charger safety,
- The combination of the active, reactive and harmonic control in a global control strategy which allows the charger to operate simultaneously with P , Q and H control, and the validation by simulation of this global strategy.

The paper is structured in the following manner: first, the control strategies to control active power (P mode) and reactive power (Q mode) are presented. Then, the harmonic control (H mode) is added with the aim of compensating the harmonic consumption of the homes, contributing to improve the power quality of the network. These strategies have been implemented in a simulation model of an energy micro-storage system located at a home of a smart community. A set of simulation tests has been carried out showing the effectiveness of the strategies in different practical situations.

2. Control Strategies

The control strategies are the general rules that must be followed by the control system in order to achieve the desired converter behavior.

2.1. Active Power

The SCEMS will manage the local ESS at homes, by sending an active power set-point to each individual ESS, according to previous market negotiations. Two modes of operation can be distinguished: Grid to battery mode (G2B- P mode) when the ESS is extracting active power to charge the batteries, and Battery to grid mode (B2G- P mode), when the ESS is injecting active power from the

batteries into the grid. The sign criterion for the set-point is positive in the G2B-*P* mode ($P_{ref} > 0$), and negative in the B2G-*P* mode ($P_{ref} < 0$).

A Direct Sinusoidal Current (DSC) control strategy is proposed [9]. This strategy aims to do that the current demanded or injected into the grid to be in phase with the fundamental component of the grid voltage. It guarantees, on the one hand, that the ESS will operate with unity displacement power factor (dPF), and on the other hand, that the charger current will have no harmonic content.

The reference charger current is [9]:

$$i_{ch-P,ref} = \frac{P_{ref}}{U_{S1}^2} u_{S1d} \quad (1)$$

where U_{S1} is the fundamental component of the grid voltage and u_{S1d} is the instantaneous value of the fundamental component of the grid voltage.

A single-phase Second-order Generalized Integrator Phase-Locked-Loop (SOGI-PLL) system [10] is employed to extract the fundamental component of the grid voltage.

2.2. Reactive Power

Local ESS at homes of smart communities can be used as distributed storage sources to provide voltage control or to improve globally the power factor of the community. Thereby, the SCEMS is responsible for calculating a fundamental reactive power set-point, Q_{1ref} , for each individual ESS. The modes of operation are G2B-*Q* mode, when the ESS is absorbing fundamental reactive power from the grid ($Q_{1ref} > 0$) and B2G-*Q* mode, when it is injecting fundamental reactive power to the grid ($Q_{1ref} < 0$).

A novel quadrature sinusoidal current (QSC) control strategy is proposed in this case, equivalent to the previous SC strategy, but taking over the reactive power, instead of the active power set-point. This strategy assures that the current demanded or injected into the grid will be sinusoidal and in quadrature with the fundamental component of the grid voltage. The reference charger current with this strategy is obtained as:

$$i_{ch-Q,ref} = \frac{Q_{1ref}}{U_{S1}^2} u_{S1q} \quad (2)$$

where u_{S1q} is the instantaneous value of the fundamental source voltage, being $+90^\circ$ phase shifted from u_{S1d} .

This component can be calculated by using the SOGI-PLL proposed in [10], since the output signals of this single-phase PLL are the fundamental component of the input signal and another component with the same amplitude but with a phase shift of 90° .

2.3. Additional Harmonic Control Strategy

If the ESS is below 100% capacity, it can be in charge of an additional function concerning the power quality improvement of the current demanded by each home and so, contributing to the global power quality consumption of the community. This harmonic control function has only a unidirectional operation mode, from the charger to the load: Battery to load mode (B2L-*H* mode).

It is important to note that this control strategy does not receive a set-point from the SCEMS, since it proposes a local compensation of the harmonic content demanded by the household circuitry. Since each home in the community has an ESS, this local compensation contributes to achieve a global compensation in the community.

A total harmonic compensation (THC) control strategy is proposed. It aims to provide as a harmonic reference charger current the whole harmonic spectrum of the current demanded by the house, neglecting the fundamental frequency. The advantage of this strategy comparing to selective harmonic compensation strategies [11] is that it can be applied for loads with unknown harmonic spectrum and requires more simplified control algorithms.

If the harmonic reference current added to the current for P and Q control exceeds the nominal current of the charger, $I_{ch,n}$, the reference current has to be limited to prevent overload. The maximum Root Mean Square (RMS) harmonic charger current is obtained from:

$$I_{ch-H,max} = \sqrt{I_{ch,n}^2 - I_{ch-P}^2 - I_{ch-Q}^2} \quad (3)$$

where I_{ch-P} and I_{ch-Q} are the RMS charger current components responsible for the P and Q control, respectively. Taking into account this limit, the reference harmonic charger current will be obtained from the following expression:

$$i_{ch-H,ref} = -\begin{cases} (i_L - i_{L1}) & \text{if } (i_L - i_{L1})_{RMS} \leq I_{ch-H,max} \\ (i_L - i_{L1}) \frac{I_{ch-H,max}}{(i_L - i_{L1})_{RMS}} & \text{if } (i_L - i_{L1})_{RMS} > I_{ch-H,max} \end{cases} \quad (4)$$

where, i_L is the load current demanded by the house, i_{L1} its fundamental component, obtained from the SOGI-PLL and $(i_L - i_{L1})_{RMS}$ is the RMS value of $(i_L - i_{L1})$.

3. ESS Power Structure and Control System

A single-phase energy micro-storage system, based on batteries, located at a home of a smart community has been developed. It receives P and Q set-points from the SCEMS and controls the current demanded/injected from/into the grid using the energy stored in the battery.

3.1. Topology

The ESS has a single-phase topology (Figure 1). It uses two power converters: one DC/DC converter to manage the charge and discharge of the battery and to adapt the battery voltage u_{bat} to the DC-link voltage U_{DC} ; and an AC/DC converter to interface with the AC grid. The DC/DC converter has a half bridge bidirectional buck-bust DC/DC topology, consisting of two transistors (S_c^+ and S_c^-) and one inductor L_2 (with resistance R_2). The AC/DC converter is a full-bridge Voltage Source Inverter (VSI) formed by four switches S_a^+ , S_a^- , S_b^+ , S_b^- and an inductor L_1 (with resistance R_1). The current drawn from the grid is i_{ch} and the current absorbed by the battery is i_{bat} .




Figure 1. Two-stage topology for the ESS bidirectional charger.


It is considered a typical consumer having 4.6 kVA contracted power (one of the standard values in Spain). It is estimated the ESS to be rated at a half of that value, so the ESS is rated at 2.3 kVA, 230 V. Therefore, the RMS nominal charger current $I_{ch,n}$ is 10 A and the main parameter values are shown in Table 1. These parameter values has been selected according to the design criteria proposed in [12].

Table 1. Main parameter values for the ESS.

Parameter	Description	Value	Unit
R_1	AC/DC converter's resistance	1×10^{-3}	Ω
L_1	AC/DC converter's inductance	30×10^{-3}	H
C	DC bus capacitor	1.1×10^{-3}	F
R_2	DC/DC converter's resistance	1×10^{-3}	Ω
L_2	DC/DC converter's inductance	15.6×10^{-3}	H
U_{iBat}	Battery's initial voltage	48	V

3.2. Global Control Strategy

The block diagram of the general control strategy is displayed in the left side of Figure 2. The control algorithm requires the measurement of several variables: the source voltage, u_s , the load current demanded by the house, i_L , the battery voltage, U_{bat} and the DC-link voltage, U_{DC} . In addition, the other inputs are the set-points P_{ref} and Q_{ref} provided by the SCEMS and the RMS nominal charger current, $I_{ch,n}$ which has a known value. In case P control or Q control are not required, the corresponding set-points are void. If harmonic control is not precise, the i_L measurement is cancelled.

**Figure 2.** Block diagram of the control system for both converters.

One can notice that there are no potential conflicts among the active, reactive and harmonic compensation, since each control is devoted to a different component of the charger current. Indeed, the lack of interaction is one of the advantages of the proposed global control strategy, which allows the charger to operate simultaneously with P , Q and H control.

The SOGI-PLL block obtains U_{S1} , u_{S1d} and u_{S1q} from the grid voltage u_s . The DSC block implements the active power from Equation (1) and adds a signal from the DC control block. This block has the objective of maintain a constant DC-link voltage; it is constituted (see at the top of the figure) by a proportional-integral (PI) controller, whose input is the difference between real and desired DC-link voltage. QSC and THC blocks (shown below the DSC) implement the reactive power control from Equation (2) and the harmonic control from Equation (4), respectively. The outputs of these three blocks are added to obtain the reference for the AC/DC converter: the reference charger current $i_{ch,ref}$.

The BC block (at the bottom on the figure) divides the P_{ref} by u_{bat} , obtaining the reference current for the DC/DC converter: the reference battery current $i_{bat,ref}$.

3.3. Switching Signal Generation

A dead-beat control technique is used to follow the reference currents $i_{ch,ref}$ for the DC/AC converter and $i_{bat,ref}$ for the DC/DC converter. Dead-beat technique is a well-known discrete control technique based on the idea of reduce to zero the error in the controlled variable at the end of the control period. Figure 3 illustrates the operation principle applied to follow $i_{ch,ref}$ in one switching period T_S . At the beginning, $i_{ch,ref}$ is compared with the measured or real charger current i_{ch} . The evolution of i_{ch} is determined by the states of the switches S_a and S_b . Indeed, when S_a^+ and S_b^- are turned on (S_a on-state) $U_{AB} = U_{DC}$ and when S_a^- and S_b^+ are on (S_a off-state) $U_{AB} = -U_{DC}$; of course the operation of the two switches of one leg is complementary. Two approximation are considered: on one hand, voltage across R_1 can be ignored compared to u_L and, on the other hand, the grid voltage u_S can be considered constant during the switching period T_S . Therefore, an approximately constant voltage is applied to inductance L_1 : $u_S - U_{DC}$ in the S_a on-state and $u_S + U_{DC}$ in the S_a off-state. Taking into account that $u_{L1} = L_1 di_{ch}/dt$, the current i_{ch} will be a positive ramp in the first case and a negative ramp in the second case; in both cases the slope value is $1/L_1$. The duty cycle ($d_1 = T_{on}/T_S$) necessary to achieve i_{ch} to be equal to $i_{ch,ref}$ at the end of T_S can be calculated from the fact that the following equality must be satisfied:

$$i_{ch,ref} - i_{ch} = \frac{(u_S - U_{DC})d_1T_S}{L_1} + \frac{(u_S + U_{DC})(1 - d_1)T_S}{L_1} \quad (5)$$

and the resulting expression for d_1 will be:

$$d_1 = \frac{(u_S + U_{DC})T_S - (i_{ch,ref} - i_{ch})L_1}{2 \cdot T_S U_{DC}} \quad (6)$$

This operation is executed by the block DBC1 (Dead-Beat Controller 1) in Figure 2, whose inputs are u_S , i_{ch} , $i_{ch,ref}$ and U_{DC} and whose output signal is d_1 .




Figure 3. Dead-beat control technique to follow a reference current.

Analogously, the duty cycle d_2 for the DC/DC converter is obtained, resulting:

$$d_2 = \frac{u_{bat}T_S - (i_{bat,ref} - i_{bat})L_2}{T_S U_{DC}} \quad (7)$$

This operation is executed by the block DBC2 (Dead-Beat Controller 2) in Figure 2, whose inputs are u_{bat} , i_{bat} , $i_{bat,ref}$ and U_{DC} ; and whose output signal is d_2 . Finally, both values d_1 and d_2 are converted into the corresponding switching signals for the gates of the converter switches by means of the Pulse Width Modulation (PWM) blocks: S_a^+ , S_a^- , S_b^+ , S_b^- for the AC/DC converter and S_c^+ , S_c^- for the DC/DC converter.

4. Simulation Results

A simulation model of the ESS has been developed in Matlab-Simulink according to the topology and control system described before. For 10 kHz switching frequency (switching period $T_S = 10^{-4}$ s), the time step for the simulation was taken $T_m = 10^{-6}$ s. The nominal RMS value of the fundamental grid voltage is 230 V, and the harmonic components are 5% 3rd harmonic, 4.5% 5th harmonic and 4% 7th harmonic. The total harmonic distortion (THD) is 7.83%, complying with the limits proposed in IEC 61000-2-2:2002 [13]. To demonstrate the behaviour of the system, the simulation has been conducted in four cases:

- Case A. Charging the battery and demanding fundamental reactive power: $P_{ref} = 1800$ W and $Q_{1ref} = 1400$ VAR. House demand without harmonics: $I_L = 10$ A (perfectly sinusoidal, i.e., $i_{Lh} = 0$).
- Case B. Discharging the battery and injecting fundamental reactive power: $P_{ref} = -1800$ W and $Q_{1ref} = -1400$ VAR. House demand without harmonics. $I_L = 10$ A (perfectly sinusoidal, i.e., $i_{Lh} = 0$).
- Case C. Charging the battery and injecting reactive power: $P_{ref} = 1000$ W and $Q_{1ref} = -600$ VAR. House demand with usual odd harmonics contents [14] below 11th order specified in Table 2; with RMS value of load current $I_L = 4.996$ A.
- Case D. Discharging the battery and demanding reactive power: $P_{ref} = -1800$ W, $Q_{1ref} = 1100$ VAR. House demand with the same usual harmonics contents; now with $I_L = 19.98$ A.

Table 2. Typical harmonic of house current.

Individual Harmonic Distortion (%)				Total Harmonic Distortion THD (%)
HD3	HD5	HD7	HD9	
25.3	9.99	12.41	6.83	30.67

Figures 4–7 show the simulation results for every case. From top to bottom and from left to right the figures present: u_S , i_{ch} , i_L , $i_{ch-H,ref}$ and i_S in steady state and u_{bat} , i_{bat} , $i_{bat-ref}$, U_{DC} and U_{DC-ref} from their initial values to steady state. It is supposed that the battery is initially charged at its nominal value (48 V). On the other hand, the AC/DC converter is supposed to operate initially as a rectifier, so as the DC-link voltage is initially at the corresponding rectified voltage ($230\sqrt{2} = 325$ V). Simulation starts at $t = 0$ and at $t = 0.05$ s the DC block starts to operate leading the DC-link voltage to its nominal value (600 V); this objective is achieved and then, at $t = 0.2$ s the all three modes (P , Q and H) are activated. To ease the visualization of transient behavior, the evolution of U_{DC} and U_{DC-ref} are shown from $t = 0$ to steady state and u_{bat} , i_{bat} and $i_{bat-ref}$ are shown from $t = 0.18$ to steady state (in this last case to show in more detail the evolution around $t = 0.2$ s). On the other hand, the evolution of u_S , i_{ch} , i_L , $i_{ch-H,ref}$ and i_S are shown for two cycles (40 ms) from 2.96 s to 3 s, when the steady state condition is reached. In all cases, the charger current i_{ch} follows the reference i_{ch-ref} accurately although the source voltage is distorted, so the ESS complies with the limits for harmonic currents produced by equipment connected to public low-voltage systems [15].




Figure 4. Simulation result. Case A. $P_{ref} = 1800$ W and $Q_{1ref} = 1400$ VAR. House demand without harmonics: $I_L = 10$ A (perfectly sinusoidal).




Figure 5. Simulation result. Case B. $P_{ref} = -1800$ W and $Q_{1ref} = -1400$ VAR. House demand without harmonics. $I_L = 10$ A (perfectly sinusoidal).




Figure 6. Simulation result. Case C. $P_{ref} = 1000$ W and $Q_{1ref} = -600$ VAR. House demand with usual harmonics content; $I_L = 4.996$ A.




Figure 7. Simulation result. Case D. $P_{ref} = -1800$ W, $Q_{1ref} = 1100$ VAR. House demand with usual harmonics contents; $I_L = 19.98$ A.

In cases A (Figure 4) and B (Figure 5) $i_{ch-H,ref}$ is null, so H function is not needed and, therefore, the charger draws from the grid a current (i_s) that differs from a sinusoid only in the switching ripple. In case C (Figure 6) the requirements from the SCEMS and the harmonic content of the house is compatible with the ESS nominal current, so the ESS performs a full compensation and the current demanded from the grid (i_s) differs from a sinusoidal only in the switching ripple. Its harmonic content is shown in Table 3. As one can see, THD is reduced from 30.67% to 2.94%. On the other hand, in case D (Figure 7) the requirements are such that it is not possible to fully attend to the harmonic compensation requirement, so ESS performs a partial compensation and in this case the current demanded from the grid (i_s) is not sinusoidal. Its harmonic content is shown in Table 4. As one can see, THD is reduced to 14.56%.

Table 3. Load and grid current harmonic content for case C.

Variable	Total RMS Value (A)		Individual RMS Value (A)				THD (%)
	I	I_1	I_3	I_5	I_7	I_9	
Load current i_L	4.996	4.78	1.21	0.48	0.59	0.33	30.67%
Grid current i_s	9.244	9.24	0.19	0.09	0.14	0.1	2.94%

Table 4. Load and grid current harmonic content for case D.

Variable	Total RMS Value (A)		Individual RMS Value (A)				THD (%)
	I	I_1	I_3	I_5	I_7	I_9	
Load current i_L	19.98	19.11	4.83	1.91	2.37	1.31	30.67
Grid current i_s	13.405	13.26	1.56	0.62	0.82	0.49	14.56

Power terms according to power definitions proposed in Std. IEEE-1459:2010 [16] are collected in Table 5 for the four cases. S is the apparent power, P is the active power, N is the non-active power, Q_1 is the fundamental reactive power, PF is the power factor and dPF is the displacement power factor.

Table 5. Power terms according to Std. IEEE-1459:2010.

Case	S (VA)	P (W)	N (VA)	Q ₁ (VAr)	PF	dPF
A	2349	1804	1504	1503	0.768	0.774
B	2335	−1796	1493	−1503	0.769	0.773
C	1228	1002	709.4	−593.6	0.8162	0.866
D	2273	−1797	1391	1072	0.7907	0.8602

5. Conclusions

Control strategies for local energy micro-storage systems regarding active power and reactive power control in the homes of smart communities have been proposed. Additionally, a control strategy to reduce harmonic content in the current demanded by the houses is presented. This control only comes into operation once the ESMS verifies that the ESS has available capacity and, if necessary, saturates the harmonic load current compensation to ensure that the charger does not exceed its nominal parameters. The main contributions of the paper are the proposal of the QSC strategy to control fundamental reactive power and the saturated THC strategy, to assure the charger safety. A 2.3 kVA single-phase energy micro-storage system based on batteries, located at a home of a smart community, has been implemented by simulation to test the proposed strategies. Simulation results showing the currents injected/demanded by the ESS charger following the set-points provided by the SCEMS with active, reactive and harmonic control are presented under distorted source conditions. These results validate the correct operation of the proposed control strategies and demonstrate that local ESS in smart communities can contribute to the smart grid goals, providing ancillary services and improving the power quality locally, thanks to the performance of the SCEMS.

Acknowledgments: This work was supported by the Spanish Ministerio de Economía y Competitividad and Fondo Social Europeo, FEDER, under Project TEC2013-47316-C3-3-P.

Author Contributions: Maria Isabel Milanes-Montero and Fermin Barrero-Gonzalez conceived, designed and supervised the simulation tests and wrote the paper, Jaime Pando-Acedo performed the simulation model and tests, Eva Gonzalez-Romera analyzed the data and simulation results, Enrique Romero-Cadaval contributed analysis tools and supervised the simulation model, and Antonio Moreno-Munoz collaborated with the paper review.

Conflicts of Interest: The authors declare no conflict of interest.

Nomenclature

d_i	Duty cycle obtained from the dead-beat controller number i
i_{bat}	Battery current
i_{ch}	Charger current
i_{ch-P}	Charger current with P mode control
i_{ch-Q}	Charger current with Q mode control
i_{ch-H}	Charger current with H mode control
$I_{ch,n}$	Nominal current of the charger
$I_{ch-H,max}$	Maximum RMS charger current available for H mode control
i_L	Load current demanded by the house
i_S	Source or grid current
P_{ref}	Active power set-point
Q_{1ref}	Fundamental reactive power set-point
T_S	Switching period
T_m	Time step for simulation
U_{bat}	Battery voltage
U_{DC}	DC bus voltage
u_S	Source or grid voltage
u_{S1d}	Fundamental component of the grid voltage
u_{S1q}	Fundamental component of the grid voltage, +90 degrees phase shifted

References

1. Davies, R.; Sumner, M.; Christopher, E. Energy storage control for a small community microgrid. In Proceedings of the 7th IET (Innovation, Engineering, and Technology) International Conference on Power Electronics, Machines and Drives (PEMD), Manchester, UK, 8–10 April 2014; pp. 1–6.
2. Sharifi, L.; Freitag, F.; Veiga, L. Combining smart grid with community clouds: Next generation integrated service platform. In Proceedings of the 2014 IEEE International Conference on Smart Grid Communications (SmartGridComm), Venice, Italy, 3–6 November 2014.
3. Li, J.; Wu, Z.; Zhou, S.; Fu, H.; Zhang, X.P. Aggregator service for PV and battery energy storage systems of residential building. *CSEE J. Power Energy Syst.* **2015**, *1*, 3–11. [[CrossRef](#)]
4. Kanchev, H.; Lu, D.; Colas, F.; Lazarov, V.; Francois, B. Energy management and operational planning of a microgrid with a PV-based active generator for smart grid applications. *IEEE Trans. Ind. Electron.* **2011**, *58*, 4583–4592. [[CrossRef](#)]
5. González-Romera, E.; Barrero-González, F.; Romero-Cadaval, E.; Milanés-Montero, M.I. Overview of plug-in electric vehicles as providers of ancillary services. In Proceedings of the 9th International Conference on Compatibility and Power Electronics (CPE), Lisbon, Portugal, 24–26 June 2015.
6. Aman, S.; Simmhan, Y.; Prasanna, V.K. Energy management systems: State of the art and emerging trends. *IEEE Commun. Mag.* **2013**, *51*, 114–119. [[CrossRef](#)]
7. Gomez, J.C.; Morcos, M.M. Impact of EV battery chargers on the power quality of distribution systems. *IEEE Trans. Power Deliv.* **2003**, *18*, 975–981. [[CrossRef](#)]
8. Onar, O.C.; Khaligh, A. Grid interactions and stability analysis of distribution power network with high penetration of plug-in hybrid electric vehicles. In Proceedings of the 25th Annual IEEE Applied Power Electronics Conference and Exposition (APEC), Palm Springs, CA, USA, 21–25 February 2010.
9. Milanés-Montero, M.I.; Gallardo-Lozano, J.; Romero-Cadaval, E.; González-Romera, E. Hall-effect based semi-fast AC on-board charging equipment for electric vehicles. *Sensors* **2011**, *11*, 9313–9326. [[CrossRef](#)] [[PubMed](#)]
10. Ciobotaru, M.; Teodorescu, R.; Blaabjerg, F. A new single-phase PLL structure based on second order generalized integrator. In Proceedings of the 37th IEEE Power Electronics Specialists Conference (PESC), Jeju, Korea, 18–22 June 2006.
11. Miret, J.; Castilla, M.; Matas, J.; Guerrero, J.M.; Vasquez, J.C. Selective harmonic-compensation control for single-phase active power filter with high harmonic rejection. *IEEE Trans. Ind. Electron.* **2009**, *56*, 3117–3127. [[CrossRef](#)]
12. González-Castrillo, P.; Romero-Cadaval, E.; Milanés-Montero, M.I.; Barrero González, F.; Guerrero Martínez, M.A. A new criterion for selecting the inductors of an active power line conditioner. In Proceedings of the 7th International Conference-Workshop Compatibility and Power Electronics CPE2011, Tallinn, Estonia, 1–3 June 2011.
13. IEC Technical Committee 77A. *Electromagnetic Compatibility (EMC)—Part 2-2: Environment—Compatibility Levels for Low-Frequency Conducted Disturbances and Signalling in Public Low-Voltage Power Supply Systems*; IEC 61000-2-2:2002; International Electrotechnical Commission (IEC): Geneva, Switzerland, 2002.
14. Suárez, J.A.; di Mauro, G.; Anaut, D.; Agüero, C. Analysis of the harmonic distortion and the effects of attenuation and diversity in residential areas. *IEEE Lat. Am. Trans.* **2005**, *3*, 53–59. [[CrossRef](#)]
15. IEC Technical Committee 77A. *Electromagnetic Compatibility (EMC)—Part 3-12: Limits—Limits for Harmonic Currents Produced by Equipment Connected to Public Low-Voltage Systems with Input Current >16 A and ≤75 A per Phase*; IEC 61000-3-12:2011; International Electrotechnical Commission (IEC): Geneva, Switzerland, 2011.
16. Std. IEEE 1459:2010. *IEEE Standard Definitions for the Measurement of Electric Power Quantities under Sinusoidal, Nonsinusoidal, Balanced, or Unbalanced Conditions*; IEEE: New York, NY, USA, 2010.

